


**SCHEDULE OF ITEMS**

ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	GATE / BALL VALVE
4	32mm - 50mm DIRT BOX WATER CORPORATION SUPPLIED
5	APPROVED WATER CORPORATION SUPPLIED WATER METER
6	TESTING FERRULE (OUTLET CAPPED) MINIMUM 20mm
7	LOW HAZARD NON-TESTABLE BACKFLOW PREVENTION DEVICE
8	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM
9	POLYETHYLENE TO COPPER CONNECTOR
<b>METERS 50mm AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK</b>	
<b>SEE GENERAL NOTES FOR FURTHER INFORMATION</b>	

**STANDARD LEGEND**

	V	Valve
	M	Meter
	D.B.	Dirt Box
	S.P.	Straight Piece
	T.F.	Testing Ferrule
	L.S.	Line Strainer
	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
	S.C.V.T.	Single Check Valve Testable
	S.C.D.A.T.	Single Check Detector Assembly Testable

DRAWING NUMBER: <h1 style="text-align: center;">4</h1>	SCALE: NOT TO SCALE	DATE: AUGUST 2014	32 - 50mm GENERAL WATER SERVICE LOW HAZARD RESIDENTIAL / COMMERCIAL / INDUSTRIAL TYPICAL ARRANGEMENT	 <b>WSC Reference</b> WSC-WSM-006
---	------------------------	----------------------	---	---