


STANDARD LEGEND

⊗	V	Valve
○	M	Meter
□	D.B.	Dirt Box
—	S.P.	Straight Piece
⊥	T.F.	Testing Ferrule
▭	L.S.	Line Strainer
∩	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
∩	S.C.V.T	Single Check Valve Testable
∩	S.C.D.A.T.	Single Check Detector Assembly Testable

SCHEDULE OF ITEMS

ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17	8	FILTER TO SUIT BACKFLOW PREVENTION DEVICE MANUFACTURER'S REQUIREMENTS
3	GATE / BALL VALVE	9	HIGH / MEDIUM TESTABLE BACKFLOW PREVENTION DEVICE TO AS2845.1
4	32mm - 50mm DIRT BOX WATER CORPORATION SUPPLIED	METERS 50mm AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK	
5	APPROVED WATER CORPORATION SUPPLIED WATER METER	SEE GENERAL NOTES FOR FURTHER INFORMATION	
6	TESTING FERRULE (OUTLET CAPPED) MINIMUM 20mm		
7	RESILIENT SEATED GATE / BALL VALVE		

DRAWING NUMBER: 5	SCALE: NOT TO SCALE	DATE: AUGUST 2014	32 - 50mm GENERAL WATER SERVICE MEDIUM/ HIGH HAZARD RESIDENTIAL / COMMERCIAL / INDUSTRIAL TYPICAL ARRANGEMENT	 WSC Reference WSC-WSM-007
-----------------------------	------------------------	----------------------	--	---