


NOTES:

- 1. A SECTION 138 APPROVAL IS REQUIRED BEFORE ANY WORK CAN COMMENCE IN COUNCIL'S ROAD RESERVE.
- 2. DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.
- 3. PROVISION FOR SERVICES UNDER SLAB TO BE INVESTIGATED PRIOR TO CONSTRUCTION. DIAL 1100 BEFORE YOU DIG.
- 4. CONTRACTOR TO NOTIFY COUNCIL'S OFFICER FOR INSPECTION WHEN (I) WORK IS PROPOSED TO COMMENCE, (II) PRIOR TO PLACING ANY CONCRETE, (III) WORK HAS BEEN COMPLETED.
- 5. A MINIMUM OF FORTY EIGHT (48) HOURS NOTICE IS TO BE GIVEN PRIOR FOR INSPECTION BY COUNCIL'S OFFICER.
- 6. THE ENTRANCE IS GENERALLY TO BE CONSTRUCTED WITHIN THE ROAD RESERVE, AT AN ANGLE OF NINETY DEGREES (90°) TO THE CENTRE LINE OF THE ROAD. THIS ANGLE MAY BE REDUCED TO A MINIMUM OF SEVENTY DEGREES (70°) WITH THE APPROVAL OF THE DEVELOPMENT ENGINEER.
- 7. COMMERCIAL FOOTPATH CROSSINGS TO BE 150mm THICK WITH SL82 REINFORCEMENT, 40mm TOP COVER. CONSTRUCT NEW GUTTER AND LAYBACK, OR TIE NEW LAYBACK INTO EXISTING GUTTER.
- 8. INDUSTRIAL FOOTPATH CROSSINGS TO BE 200mm THICK WITH SL102 REINFORCEMENT, 40mm TOP COVER. RECONSTRUCT LAYBACK AND GUTTER. RESTORE ROAD EDGE.
- 9. SPECIFIED CONCRETE STRENGTH SHALL BE F'c 32MPa.
- 10. PROVIDE SAW CUT CONTRACTION JOINTS (C.J.) AT 4m MAXIMUM SPACING IN EACH DIRECTION. REFER SD151 FOR DETAIL.
- 11. SLAB BASE COURSE TO BE 100mm DEEP ROAD BASE, THICKENED TO 150 UNDER KERB & GUTTER.
- 12. COMPACT SUB-GRADE AND BASE COURSE TO 95% STANDARD COMPACTION.
- 13. PROVIDE HOT DIPPED GALVANISED R20 DOWELS ALONG EXPANSION JOINT, 350 LONG, 300 CENTRES. PROVIDE BOND BREAK TO ONE HALF OF DOWEL.
- 14. DRIVEWAY SHALL HAVE A "NON SLIP" LIGHT BROOM FINISH.
- 15. REFER TO AS 2890.2-2002 FOR DRIVEWAY WIDTH (W2).
- 16. FORTY EIGHT (48) HOURS NOTICE IS TO BE GIVEN PRIOR TO PLACING OF CONCRETE TO ALLOW FOR INSPECTION BY COUNCIL'S OFFICER.

DESIGN	VEHICLE	ENTRY	WIDTH	(W1)	DRIVEWAY	WIDTH	(W2)
S.R.V.	(6.4m)		6m		REFER AS		
M.R.V.	(8.8m)		9m				
H.R.V.	(12.5m)		12.5m 289		2890.	.2-2002	
A.V. (19.0m)		12.5m				





GROUP MANAGER INFRASTRUCTURE SERVICES D.L.

WINGECARRIBEE SHIRE COUNCIL

STANDARD DRAWING - COMMERCIAL &

STANDARD DRAWING — COMMERCIAL & INDUSTRIAL VEHICULAR CROSSING

DATE: 25/01/2021 PLAN No: SD108 SHEET 1 OF 1 ISSUE B