

CERTIFICATE OF ANALYSIS

Work Order : **EW1703437**
Client : **WINGECARRIBEE SHIRE COUNCIL**
Contact : MR CHRIS MURPHY
Address : PO BOX 141
 MOSSVALE NSW
 AUSTRALIA
Telephone : ----
Project : RRC Quarterly
Order number : ----
C-O-C number : ----
Sampler : Robert DaLio
Site : ----
Quote number : WO/067/12
No. of samples received : 7
No. of samples analysed : 7

Page : 1 of 5
Laboratory : Environmental Division NSW South Coast
Contact : Glenn Davies
Address : 1/19 Ralph Black Dr, North Wollongong 2500
 4/13 Geary Pl, North Nowra 2541
 Australia NSW
Telephone : 02 42253125
Date Samples Received : 11-Aug-2017 12:48
Date Analysis Commenced : 11-Aug-2017
Issue Date : 18-Aug-2017 14:19



Accreditation No. 825
 Accredited for compliance with
 ISO/IEC 17025 - Testing

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Ankit Joshi	Inorganic Chemist	Sydney Inorganics, Smithfield, NSW
Glenn Davies	Environmental Services Representative	Laboratory - Wollongong, NSW
Raymond Commodore	Instrument Chemist	Sydney Inorganics, Smithfield, NSW



General Comments

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When no sampling time is provided, the sampling time will default 00:00 on the date of sampling. If no sampling date is provided, the sampling date will be assumed by the laboratory and displayed in brackets without a time component.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.

- TDS by method EA-015 may bias high for sample 6 due to the presence of fine particulate matter, which may pass through the prescribed GF/C paper.
- EN055: Ionic Balance out of acceptable limits for sample 1 due to analytes not quantified in this report.
- Sampling and sample data supplied by ALS Wollongong.
- Sampling completed as per FWI-EN001 Groundwater Sampling.
- Sampling completed as per FWI-EN002 Surface Water Sampling.
- Field tests completed on day of sampling/receipt.



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID	EPA 1	EPA 2	EPA 3	EPA 5	EPA 6
Client sampling date / time				11-Aug-2017 11:30	11-Aug-2017 10:00	11-Aug-2017 10:25	11-Aug-2017 11:00	11-Aug-2017 11:45	
Compound	CAS Number	LOR	Unit	EW1703437-001	EW1703437-002	EW1703437-003	EW1703437-004	EW1703437-005	
				Result	Result	Result	Result	Result	
EA005FD: Field pH									
pH	----	0.1	pH Unit	6.2	4.3	5.1	----	8.4	
EA010FD: Field Conductivity									
Electrical Conductivity (Non Compensated)	----	1	µS/cm	5010	503	2540	----	773	
EA015: Total Dissolved Solids dried at 180 ± 5 °C									
Total Dissolved Solids @180°C	----	10	mg/L	3550	268	1330	----	455	
ED037P: Alkalinity by PC Titrator									
Hydroxide Alkalinity as CaCO3	DMO-210-001	1	mg/L	<1	<1	<1	----	----	
Carbonate Alkalinity as CaCO3	3812-32-6	1	mg/L	<1	<1	<1	----	----	
Bicarbonate Alkalinity as CaCO3	71-52-3	1	mg/L	156	<1	5	----	----	
Total Alkalinity as CaCO3	----	1	mg/L	156	<1	5	----	----	
ED041G: Sulfate (Turbidimetric) as SO4 2- by DA									
Sulfate as SO4 - Turbidimetric	14808-79-8	1	mg/L	111	<1	<1	----	----	
ED045G: Chloride by Discrete Analyser									
Chloride	16887-00-6	1	mg/L	1120	148	768	----	----	
ED093F: Dissolved Major Cations									
Calcium	7440-70-2	1	mg/L	216	<1	10	----	----	
Magnesium	7439-95-4	1	mg/L	160	7	37	----	----	
Sodium	7440-23-5	1	mg/L	624	80	435	----	----	
Potassium	7440-09-7	1	mg/L	17	<1	<1	----	----	
EK055G: Ammonia as N by Discrete Analyser									
Ammonia as N	7664-41-7	0.01	mg/L	0.02	0.12	0.01	----	0.11	
EN055: Ionic Balance									
Total Anions	----	0.01	meq/L	37.0	4.17	21.8	----	----	
Total Cations	----	0.01	meq/L	51.5	4.06	22.5	----	----	
Ionic Balance	----	0.01	%	16.4	1.44	1.58	----	----	
EN67 PK: Field Tests									
Field Observations	----	0.01	--	----	----	----	DRY	----	
EP005: Total Organic Carbon (TOC)									
Total Organic Carbon	----	1	mg/L	14	7	4	----	23	
EP030: Biochemical Oxygen Demand (BOD)									
Biochemical Oxygen Demand	----	2	mg/L	----	----	----	----	13	
FWI-EN/001: Groundwater Sampling - Depth									



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID	EPA 1	EPA 2	EPA 3	EPA 5	EPA 6
Client sampling date / time					11-Aug-2017 11:30	11-Aug-2017 10:00	11-Aug-2017 10:25	11-Aug-2017 11:00	11-Aug-2017 11:45
Compound	CAS Number	LOR	Unit		EW1703437-001	EW1703437-002	EW1703437-003	EW1703437-004	EW1703437-005
					Result	Result	Result	Result	Result
FWI-EN/001: Groundwater Sampling - Depth - Continued									
Depth	----	0.01	m		3.75	2.31	2.36	----	----



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)		Client sample ID		EPA 7	EPA 4	----	----	----
Client sampling date / time		11-Aug-2017 10:55		11-Aug-2017 10:40		----	----	----
Compound	CAS Number	LOR	Unit	EW1703437-006	EW1703437-007	-----	-----	-----
				Result	Result	----	----	----
EA005FD: Field pH								
pH	----	0.1	pH Unit	8.0	7.8	----	----	----
EA010FD: Field Conductivity								
Electrical Conductivity (Non Compensated)	----	1	µS/cm	5320	1800	----	----	----
EA015: Total Dissolved Solids dried at 180 ± 5 °C								
Total Dissolved Solids @180°C	----	10	mg/L	4570	1110	----	----	----
EK055G: Ammonia as N by Discrete Analyser								
Ammonia as N	7664-41-7	0.01	mg/L	78.2	4.15	----	----	----
EP005: Total Organic Carbon (TOC)								
Total Organic Carbon	----	1	mg/L	1300	123	----	----	----
EP030: Biochemical Oxygen Demand (BOD)								
Biochemical Oxygen Demand	----	2	mg/L	946	89	----	----	----